

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 407

Dated: 17/06/2023

It is certified that an inspection team headed by DR. C.S.P CHAUDHARY.

(Name of Officers with designation) from MOIC, CHC/PHC RAHUI

(Name of Department/ Office) inspected the HEALTH DEPARTMENT BIHAR

(Name & Address of the school) on 17/6/2023 (date of inspection) and found that the GOLDEN BELL PUBLIC SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of ONE YEAR.

Signature with Seal: [Signature] 17/06/2023

Name : [Signature]

Designation : सामाजिक स्वास्थ्य क्षेत्र

Name & Address of the Office / Department : राहई (नालंदा)

To

GOLDEN BELL PUBLIC SCHOOL

NH 31 MORA TALAB, BIHAR SHARIF

NALANDA

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English to be uploaded along with the original vernacular certificate as a single pdf.

Bipin Kumar Singh
ManagerGolden Bell Public School
NH-20, Mora Talab, Bihar Sharif (Nalanda)A. Singh
PrincipalGolden Bell Public School
NH-20 Mora Talab, Bihar Sharif (Nalanda)



DISTRICT LEVEL LABORATORY, PHED



PUBLIC HEALTH DIVISION, MOGALKUAN, BIHARSHARIF, NALANDA BIHAR, INDIA

TC-10498

TEST REPORT

Name & Address Of the Customer :	URL No-	TC-104982300000232F
	Report No.	: BS/W/23-24/R/232
Block :- Rahul Panchayat :- Mora Talab Location :- Golden Bell Public School W no :-	Date	: 27/07/2023
	Sample No.	: BS/W/23-24/232
Sample Description	: Drinking Water	Block :- Rahul
	Panchayat :- Mora Talab	Location :- Golden Bell
Sample Mark/ Location	Public School	W no :-
Sample Collected On	: 08/06/2023	
Sampling Plan & Method	: IS 3025(Part 1): 1987 (RA 2019)	
Date of Performance (s)	: 27/07/2023 - 28/07/2023	
Ref No. Date	:	

Analysis Result

Sl. No.	Test Parameter	Test Method	IS 10500:2012Amd. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	. pH at 25 °C	IS 3025(Part 11) : 2017	6.65-8.5	NR	7.93
2	2. Turbidity at NTU	IS 3025(Part 10) : 2017	1.0	5.0	0.73
3	3. TDS at mg/l	IS 3025(Part 16) : 2017	500	2000	450
4	4.Total Hardness at mg/l	IS 3025(Part 21) : 2019	300	1000	180
5	5.Calcium at mg/l	IS 3025(Part 40) : 2019	200	600	48
6	6. Magnesium at mg/l	IS 3025(Part 46) : 2019	75	200	17
7	7. Iron at mg/l	APHA 23rd Edition -3500-Fe Method B (Phenanthroline Method) : 2017	1.0	NR	0.07
8	8. Chloride at mg/l	IS 3025(Part 32) : 2019	250	1000	40
9	9. Total Alkalinity at mg/l	IS 3025(Part 23) : 2019	200	600	205
10	10. Fluoride at mg/l	APHA 23rd Edition -4500-F Method C (Electrode Method) : 2017 / APHA 23rd Edition -4500-F Method D (SPADNS Method) : 2017	1.0	1.5	0.9
11	11. Colour at HU	IS 3025 (Part 4) : 2017	5.0	15.0	<1
12	12. Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable
13	13. Taste	IS 3025 (Part 8) : 2017	Agreeable	Agreeable	Agreeable

Disclaimer:

- The result relates only to the item(s) tested
- The report shall not be reproduced except in full, without approval of the laboratory

The reserved part of water sample(s) shall be retained for 30 days from the date of issue of the Test Report.

Reviewed & Authorized By

Rajesh Kumar
28/07/2023
Authorized Signatory
Chemist

DLWTL, Biharsharif

G. Singh
Principal

Golden Bell Public School

Golden Bell Public School
NH-20, Mora Talab, Bihar Sharif (Nalanda)

